

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

DAS SOLAR CO., LTD.

No.43, South of Bailing Rd., Quzhou Green Industry Clustering Zone
Quzhou City, Zhejiang Province, 324000
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Flexible PV module with 6" 1/6-cut Mono Cells



Valid from: 2020-12-24

Valid until: 2025-09-02

Tested according to: IEC / EN 61215-1:2016;
IEC / EN 61215-1-1:2016;
IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018;
IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018;
IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.

Registered No.: 44 780 20 406749 - 127R1M1

Manufacturer: see Annex 1

Test Report No.: 492011471.002

File No.: PVP12004/20P



Essen, 2020-12-24

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: **44 780 20 406749 - 127R1M1**

Seite / Page **1** von / of **1**

Aktenzeichen: / File reference: **PVP12004/20P**

2020-12-24

Manufacturer:

Manufacturer: **DAS SOLAR CO., LTD.**
No.43, South of Bailing Rd., Quzhou Green Industry Clustering Zone
Quzhou City, Zhejiang Province, 324000, P.R. China

Factory inspection report no.: **862010455.002**

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

A handwritten signature in blue ink, appearing to read "Robin Miao". The signature is fluid and cursive, written in a professional style.

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	Flexible PV module with 6" 1/6-cut Mono Cells: 396 cells: DAS-LOCP-xxx (xxx = 275 - 335, in increment of 5) 264 cells: DAS-LOEP-xxx (xxx = 185 - 225, in increment of 5) 132 cells: DAS-LOFP-xxx (xxx = 95 - 110, in increment of 5) 96 cells: DAS-LOHP-xx (xx = 70 - 80) 66 cells: DAS-LOGP-xx (xx = 45 - 55)
Maximum system voltage:	1000V
Fuse rating:	15A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	1600 / 1600
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products